


ted and Certified by MO R&T to NSF/ANSI 61 NSE/ANSI 372 for least

ATEDIALCLICT

UP667 & UP668 ¼"-2"

Brass Gate Valve for Potable Water 200 WOG Threaded Bonnet Threaded Ends (UP667) • Solder Ends (UP668)

ITEM	PART	MATERIALS	ASTM SPEC.					
1	Handwheel Nut	Brass	B16 C36000					
2	Nameplate	Aluminum Sheet	Commercial					
3	Handwheel	Cast Iron	A48, Class 35					
4	Stem	Brass	B283 C27450					
5	Packing Nut	Forged Brass	B283 C27450					
6	Gland	Brass Rod	B283 C27450					
7	Packing Ring	PTFE	Commercial					
8	Bonnet	Forged Brass	B283 C27450					
9	Locknut	Brass Rod	B283 C27450					
10	Wedge	Forged Brass	B283 C27450					
11	Body	Forged Brass	B283 C27450					



DIMENSIONS

Units	Size	Α	В	C	D	Cv
INCHES	1/4	1.63	2.84	2.13	-	
mm		41	72	54		5.6
INCHES	3/8	1.63	2.84	2.13	1.63	10.7
mm		41	72	54	41	
INCHES	1/2	1.69	2.91	2.13	1.78	17.6
mm		43	74	54	45	
INCHES	3/4	1.84	3.31	2.13	2.31	32.0
mm		47	84	54	59	
INCHES	1	2.19	3.94	2.41	2.84	54.0
mm		56	100	61	72	
INCHES	1 1/4	2.42	4.34	2.94	3.00	97.0
mm		61	110	75	76	
INCHES	1 1/2	2.44	4.94	2.94	3.22	135.0
mm		62	125	75	82	
INCHES	2	2.84	6.03	3.19	3.97	230.0
mm		72	153	81	101	

Note: Lead free refers to the wetted surface of the pipe, fittings and fixtures in potable water systems that have a weighted average lead content $\leq 0.25\%$. Source: California Health and Safety Code (116875).

The information presented on this sheet is correct at time of publication. Milwaukee Valve reserves the right to change design and/or materials without notice. For our Installation, Operation and Maintenance Manual and the most current product information go to www.milwaukeevalve.com.

UP-30